



Product Service

Attestation of Conformity

No. N8 12 10 73900 015

Holder of Certificate: **Zhejiang Chint Electric Co., Ltd.**

No.1, Chint Road, Chint Industrial Zone
North Baixiang
325603 Yueqing, Zhejiang
PEOPLE'S REPUBLIC OF CHINA

Product:

**Tubular fuses
Fuse and Fuse base**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.:

704101039303-02



Date, 2012-11-21

(Yi Zhu)



After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 2

Attestation of Conformity
No. N8 12 10 73900 015



Product Service

Model(s):

Fuse:

RT36-00, RT36-1, RT36-2, RT36-3, RT36-4

Fuse-base:

RT36-00, RT36N-00; RT36-1, RT36N-1;

RT36-2, RT36N-2; RT36-3, RT36N-3;

RT36-4, RT36N-4.

Parameters:

Rated voltage:

RT36-00: AC500V/AC660V/AC690V/DC250V

RT36-1, RT36-2, RT36-3: AC500V/AC660V/AC690V/DC440V

RT36-4: AC500V, DC440V

Rated current:

RT36-00: 4A, 6A, 10A, 16A, 20A, 25A, 32A, 35A, 40A,
50A, 63A, 80A, 100A, 125A, 160A

RT36-1: 80A, 100A, 125A, 160A, 200A, 224A, 250A

RT36-2: 125A, 160A, 200A, 224A, 250A, 300A, 315A,
355A, 400A

RT36-3: 315A, 355A, 400A, 425A, 500A, 630A

RT36-4: 800A, 1000A, 1250A

Poles No.: 1-P

Breaking range and
utilization category: gG

Rated breaking capacity:

RT36-00: 120kA(AC500V), 50kA(AC660V/AC690V), 100kA(DC250V)

RT36-1, RT36-2, RT36-3: 120kA(AC500V),
50kA(AC660V/AC690V), 100kA(DC440V)

RT36-4: 120kA (AC500V), 100kA (DC440V)

**Tested
according to:**

EN 60269-1:2007

HD 60269-2:2007