

GINDRE DUCHAVANY

INSPECTION CERTIFICATE 3.1 EN 10204		Date: 13/11/2019 Nr : RCF232979-0	
MGI S.A. AV. GRAL. FLORES 2199 . MONTEVIDEO-URUGUAY URUGUAY		Our Order Nr : GD084277*2 - F627985	Order Qty : 15 P
		Your Order Nr: PEDIDO DEL 23/10/2019	
CUETP HRF77-91 BARRA DE COBRE 50X10MM CANTADO MATADO (1MM) IN 4000MM-0/+100 ASTMB152 CAJAS MARITIMAS			
ASTM B152 Drawing Nr : Your Item Ref : BC50X10		CUA1 HRF77-91 50X10 R1 BA CW004A/CuA1/E-Cu57/C101/_/C11000	
Parameters	Min	Max	Values
WIDTH	49.8	50.2	49.91 mm
THICKNESS	9.92	10.08	9.95 mm
CONDUCTIVITY	97.16		100 %IACS
HARDNESS HRF	77	91	82.7
TENSILE STRENGTH	245	350	278 N/mm ²
ELONGATION	15		28.91 %
COPPER CONTENT	99.9		99.99 %
SILVER CONTENT	99.9		%
WEIGHT CONTROLLED (KG)			271.00
This certificate is generated automatically and valid without personal sign We hereby certify that the material described above complies with terms of the order contract			
Certificat ISO 9001 INTERTEK 0044840-00	Page: 1/1		Quality ASSURANCE D. PEDRO Jean Paul